

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214831
Address: 1525 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, November 21, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-post permanent address numbers-provide as graded plot plan-pay outstanding fees-guardrail required at front porch-install front door hardware-repair rock at garage ceiling-provide handrail garage stairs-no more than 3/8" variance between garage stair rises-garage door must self closing-repair rock at 2nd floor bath vanity outlet-remove access cover at jacuzzi tub master bath for inspection-support DWV 3" line at basement behind water heater-provide ladder at basement egress window-splash blocks, min 36" discharge from foundation-Sump pump 36" discharge from foundation
---	------	---

Comments: