

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213593
Address: 2143 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Monday, November 21, 2022

Corrective Action Required:

1	Misc	- Pay all fees - irrigation permit submit a back flow certification - Splash blocks to discharge minimum of 36" away from foundation - Provide 6" clearance siding to grade
---	------	--

TCO expiration 10/29/22

Comments: