CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215281

Address: 3651 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643651 NE AKIN DR, Unit:C, LEES SUMMIT, MO

640643651 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643651 NE AKIN DR, Unit:E, LEES

SUMMIT, MO 640643651 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Gas Service Inspection - Khanh Nguyen Failed Tuesday, November

Commercial 22, 2022

Corrective Action Required:

1 Misc -Gas test fails for unit E. Pressure not holding

Comments: