

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Michael Harkins	Partial	Tuesday, November 22, 2022

Informational:	
1 Misc	PARTIAL PASS ELECTRICAL CONDUIT WEST TRANSFORMER ABOUT 60' EAST TO GATE - IT CONDUIT FRONT OF BUILDING TO SIDEWALK OK TO COVER - - 11/22/22 CONDUIT FOR (7) LIGHT POLE BASES OK TO BACKFILL -

Comments: