## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20220590

Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Michael Harkins Failed Tuesday, November

Commercial 22, 2022

Corrective Action Required:

1 Miscellaneous - 11/22/22 LIGHT POLE BASES
Correction NO DRIVEN GROUND RODS

PROVIDE REBAR CAGES PER CITY APPROVED PLANS SHEET ES101

**Comments:**