

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215943
Address: 3234 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, November 22, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Nail all exterior corners of garage- Provide (2) 2x10 joist per plan for roof support garage- Strap top plate garage at breeze way no over lap- Replace damaged stud back wall garage left bay- Rafter collar ties garage every 4'- Security blocking sliding door breeze way- Provide (2)2x10 breeze way per plans- Provide 4" ductwork for main floor bathroom vent- Provide 2x10" header over fire place per plans- Fb fur out stairs to basement- Provide protection plate for nm stairs landing 6 studs pack- Provide egress windows basement- Solid block cantilever basement- Protect nm wiring within 6' of attic access- Address rafters landing on blocks master shower and closet- Bathroom vent ductwork second floor to 4" |
|---|--------------------------|--|

Comments: