

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216073  
Address: 520 SE DAVID RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Tuesday, November 22, 2022

Corrective Action Required:

1	Misc	-driveway and sidewalk inspections toons required, contact development services to schedule -no covered deck piers inspection performed -set attic access cover at garage -spindles at basement stairs -Install outlet at master vanity -set outlets and cover plates at wet bar -splash blocks -set sewer tracer box to grade
---	------	---

Comments: