

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216468
Address: 455 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------------------------------|-----------------|----------|----------------------------|
| Occupancy Inspection - Codes Commercial | Michael Harkins | Failed | Tuesday, November 22, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Miscellaneous Correction | Provide hammer arrestor dishwasher Break Room #111 Provide GFCI protection dishwasher #111 Label service panels Room #133 Provide GFCI protection Draw room sink #108 Provide restroom signage patient unisex Room #122 |
|---|--------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

: OK TO STOCK & TRAIN :

Comments: