

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220894

Address: 1025 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1027 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1029 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1023 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|----------------------------|
| All Rough Inspection - Commercial | Robb Popp | Failed | Tuesday, November 22, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | 1023- Remove bonding screw from panel, Bocca plates at bath , address damaged truss at master, Bocca plate at master top plate |
| | | 1025- Nail exterior corners, damaged truss at entryway, top plate penetration master bath, protect nm at master ceiling, seal dead spaces at hvac |
| | | 1027- Strap top plate at garage,provide bonding screw and jumper kitchen, protect dryer ducts at laundry, seal hvac chase, |
| | | 1029- Seal top plate at garage, protect dryer duct |

Comments:

