

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Tuesday, November 22, 2022

Corrective Action Required:

1	SECOND FLOOR	AREA "A" Complete AREA B 2001
---	--------------	--

Corrective Action Required:

2	THIRD FLOOR	Complete AREA B 3001
---	-------------	--------------------------------

Corrective Action Required:

3	FOURTH FLOOR	AREA "A" complete Area B 4017-missing cover plate at fire wall, remove putty packs 4001,4002
---	--------------	--

Corrective Action Required:

4	FIFTH FLOOR	AREA "A" complete AREA B 5017-seal penetrations at elevator in lobby
---	-------------	--

5001-Seal penetration in elevator
5002-Seal penetration at ductwork

Comments: