

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201796
Address: 2309 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Passed	Wednesday, November 23, 2022

Informational:

1 Misc

On 11/22/2021 I performed a sidewalk inspection and pass the subgrade to pour concrete

11-9-22 RH. Two panels were cracked and will need replaced before passing.

11-21-22 RH. Sidewalk is formed up and aggregate is placed and compacted.

11-23-22 RH. Sidewalk passed LS and ADA specification.

Comments: