

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222785
Address: 1220 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Michael Harkins	Partial	Wednesday, November 23, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- sanitary main trunk lines clean out every 100', floor drain & vents Grid line K east to west Grid line F east to west Grid line B east to west -
---	--	---

Comments: