

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20222496

Address: 2501 NE COLBERN RD, LEES SUMMIT, MO 640862601 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                    | Inspector: | Outcome: | Date:                           |
|--------------------------------|------------|----------|---------------------------------|
| <b>Pavement-Aggregate Base</b> | Adam Nacke | Partial  | Wednesday,<br>November 23, 2022 |

Informational:

|   |      |                                                                   |
|---|------|-------------------------------------------------------------------|
| 1 | Misc | 11-21-22 AN. Road is cut and spalding is starting to lay geo grid |
|   |      | 11-21-22 AN. Geo grid in Tenax 302 and 10in of rock               |
|   |      | 11-21-22 AN pic attached of geo grid                              |
|   |      | 11-22-22 AN spalding is still putting down aggregate base         |
|   |      | 11-23-22 AN. Compacting the base and doing some clean up          |

**Comments:**