

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222496

Address: 2501 NE COLBERN RD, LEES SUMMIT, MO 640862601 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Detention Basin	Adam Nacke	Partial	Wednesday, November 23, 2022

Corrective Action Required:

1	Miscellaneous Correction	11-10-22 AN 1 of the basin appears to be completed but since we ran out of time for vegetation, skimmers need to be installed on both basins 11-23-22 AN putting rock around the out flow to stop silt from going into the storm system
---	-----------------------------	--

Comments: