

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212842
Address: 1900 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, November 23, 2022

Corrective Action Required:

1	Misc	-no access to jacuzzi tub motor master bedroom with current configuration, motor on opposite end of tub IRC P2720.1 (CURRENT CONFIGURATION OF ACCESS PANEL AT REC ROOM THROUGH FURRED DOWN AND SUB FLOOR DOESN'T RESULT IN SPACE REQUIRED TO MEET THE INTENT OF THE CODE WHICH IS TO PROVIDE UNOBSTRUCTED SPACE IN ORDER TO PERMIT REMOVAL AND REPLACEMENT OF THE CIRCULATION PUMP)
---	------	---

Comments: