CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526

904 NW PRYOR RD, LEES SUMMIT, MO 64081 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Michael Harkins Partial Friday, November 11,

2022

Corrective Action Required:

1 THE FOLLOWING 2 HOUR WALL TYPE P1 UL U301

> AREAS ARE 1ST LAYER 5/8 TYPE X NORTH SIDE OK

APPROVED 2ND LAYER 5/8 type X NORTH SIDE OK TO TAPE

R19 INSULATION INSTALLED WALL TYPE P1

: NOTE FIRE CAULK ALL PENETRATIONS & ROOF DECK :

Comments: