

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Monday, November 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	ROUGH FRAMING Install doors & windows solid block sheathing breaks above south door provide documintation flashing at windows on wood sill -Complete all meps
---	--------------------------	---

Comments: