

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20216468  
Address: 455 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Monday, November 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide hammer arrestor dishwasher Break Room #111 Provide GFCI protection dishwasher #111
---	--------------------------	---

: OK TO STOCK & TRAIN :

**Comments:**