

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216100  
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Tuesday, November 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	RESTORE EROSION CONTROL ALONG THE STREET. A SIGNIFICANT AMOUNT OF MUD WAS DEPOSITED ON THE STREET. THE STREET SHALL BE CLEANED UP IMMEDIATELY. FAILURE TO COMPLY WITH THE ABOVE WILL RESULT IN AN ISSUANCE OF STOP-WORK ORDER
---	--------------------------	---

**\*\*11/29 EROSION CONTROL SIGN POSTED**

**Comments:**