

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220894

Address: 1025 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1027 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1029 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081
1023 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Tuesday, November 29, 2022

Corrective Action Required:

1	Misc	1025- Nail exterior corners-LIVING ROOM, MASTER BED, REPAIR DAMAGED TRUSS UPSTAIRS PER ENGINEERED CORRECTION, protect nm at master ceiling-NOT DONE
		1029- protect dryer duct 2" below plate line

Comments: