

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220114  
Address: 2035 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, November 29, 2022

Corrective Action Required:

1	Misc	-mid way strap all dwv in stud bays 2" in diameter or less -boca plate for dwv protection at garage S wall -complete cspf in dinning -fireblock W laundry wall to ceiling space (seal gaps -fireblock vertically to horizontally every 10' in basement -missing nail in hanger at double 2x12 above stairs -revise plans to show new deck extended out and outdoor fireplace. Will inspect outside at time of deck revisions and cspf completion
---	------	---

Comments: