

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216304  
Address: 3201 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                      |
|-------------------------------------------------|------------------|----------|----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Tuesday, November 29, 2022 |

Corrective Action Required:

|   |      |                                                                                |
|---|------|--------------------------------------------------------------------------------|
| 1 | Misc | -spark ring as required by code for kitchen outlets where greater than 3/8 gap |
|---|------|--------------------------------------------------------------------------------|

**Comments:**