



November 28, 2022

Summit Homes  
120 SE 30<sup>th</sup> St  
Lee's Summit, MO 64082

**RE: Post Pour Deck Piers Inspection for Lot # 197 Woodside Ridge – 2217 NW Killarney Ln  
Lee's Summit, MO 64081 – Permit # PRRES20222754**

On November 28, 2022, an inspection was performed by Everstead at the above referenced property. The purpose of this inspection was to verify footing forms and rebar meet permit plan specifications.

- The soils observed at footing elevation were a competent clay soil with no apparent compaction or moisture issues.
- Deck pads were verified by pictures
- Everstead did an on-site post pour inspection of the piers
- Everstead has determined that the deck piers were constructed to permit plan specifications

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

