

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215280

Address: 3659 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643659 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Passed	Wednesday, November 30, 2022

Informational:

1 Misc

UNIT C:

-I'm seeing gap at 3" vent roof flashing above rear bathroom sink. This might be a hole in the flashing

Comments: