

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081 520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, November 30, 2022

Corrective Action Required:

1	SECOND FLOOR	AREA "A" Complete AREA B COMPLETE EXCEPT AS NOTED: **COMPLETE ELECTRICAL AND SEAL PENETRATIONS AT STAIRWELL 3
---	--------------	---

Corrective Action Required:

2	THIRD FLOOR	Complete
---	-------------	----------

Corrective Action Required:

3	FOURTH FLOOR	COMPLETE
---	--------------	----------

Corrective Action Required:

4	FIFTH FLOOR	COMPLETE
---	-------------	----------

Corrective Action Required:

5	FIRST FLOOR	Parking lobby 1002- Missing cover plate, support lv wires off of grid, support line sets, complete mechanical **OK for borders
---	-------------	---

Comments: