

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216533
Address: 509 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, November 30, 2022

Corrective Action Required:

1	Misc	-GUARDRAIL REQUIRED AT FRONT PORCH, 30" OR MORE FROM GRADE -DOWNSPOUT DISCHARGE MUST EXTEND MIN 36" DISTANCE FROM FOUNDATION -no more than 3/8" variance between riser heights at garage stairs -hot water heater discharge pipe min 2X pipe diameter AFF, maximum 6" AFF
---	------	--

Comments: