

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20221459
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Eric Sharp	Partial	Wednesday, November 30, 2022

Informational:

1	Misc	Bair crew on site grading and cutting roadways. Spoke with Shane on 11/16/22 about possibility of laying fly ash and tilling into roadway as a measure to help dry subgrade in preparation of laying geogrid and aggregate base. 11/17/22 ES
		Bair crew grading roadways, dug out areas in front of some inlet boxes to take out wet fill and recompact with more suitable fill. 11/21/22 ES
		11-30-22 RH. Contractor continued to place rock on top of Geogrid. 10" on aggregate is being placed on geo grid to reach proper stabilization.

Comments: