

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220426
Address: 102 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, November 30, 2022

Corrective Action Required:

1	Misc	-Provide accessible restroom signage 48"-60" aff to braille on latch side of door -Provide open faced toilet seat -Mirror to be max 40" to reflective surface -Non absorbant baseboard and wall finish required in restroom min of 48" aff -Stair risers at exterior to be within 3/8" variance -Mount fire extinguisher
---	------	---

Comments: