

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213189
Address: 1912 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------------|--------------|----------|---------------------------------|
| Occupancy Inspection - Codes Residential | Khanh Nguyen | Failed | Wednesday, November 30, 2022 |

Corrective Action Required:

| | | |
|---|------|--------------------------------------------------------------------------------------------|
| 1 | Misc | -Complete lawn irrigation permit application and submit backflow valve test report to city |
| | | -Install tamper-proof caps at AC valves |
| | | -Provide sewer tracer wire port at grade |

Comments: