

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220180
Address: 525 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, November 30, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- no pier inspection performed on covered patio piers-maintain erosion control on lot until sod is placed-pan off fireblock cantilevers at garage-label all dedicated receptacles at garage and unfinished space as not GFCI protected-garage door must be self closing, adjust spring hinges-install cover plate at pantry-hot water heater discharge pipe min 2X pipe diameter AFF, maximum 6" AFF-AFCI protection required at washer circuit-sod-splash blocks-seal all penetrations in siding-uncover water meter lid
---	------	--

Comments: