

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220891

Address: 1014 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811016 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811018 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811012 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Wednesday, November 30, 2022

Corrective Action Required:

1	Misc	Protect dryer duct 2" below plate line throughout
---	------	---

1012-strap top plate at master
1014-dryer duct
1016-dryer duct
1018-Set screws at holddowns in master closet and back bed, seal
fireblocking at ceiling line in master, provide bonding screw and jumper at
exterior box

Comments: