CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20214592		
Address:	809 NE ALGONQUIN ST, LEES SUMMIT, MO 64064807 NE ALGONQUIN		
	LEES SUMMIT, MO 64064805 NE ALGONQUIN ST, LEES SUMMIT, MO		
	64064		
Inspected On:	Thursday, December 01, 2022		
Inspected By:	Khanh Nguyen		
Expiration Date:	2/1/2022 12:00:00 AM		

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, December 01, 2022

Corrective Action Required:

1 Misc

UNIT 805:

- Obtain an irrigation permit.

UNIT 809: -Obtain lawn irrigation permit and submit backflow valve test report to city

-Water meter-to-lid distance exceeds city spec. (14"-18")

**TCO approved for unit 805 and 809 only.