

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215475
Address: 3069 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Partial	Thursday, December 01, 2022

Informational:

1	Misc	11-29-22 RH. Driveway was wider than 36' and mud needed to be removed and aggregate placed back in and compacted.
		12-1-22 RH. Driveway was adjusted to meet LS requirements. Forms were placed and aggregate was placed and compacted. Approved to pour once temperature is suitable.

Comments: