

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220708
Address: 3204 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, December 01, 2022

Corrective Action Required:

1 Misc

- uncover covered pfg exter nailing at garage
- fire block dwv N garage wall into furr down
- nail all intersecting exterior wall corners to code
- address holes drilled in joists closer than 2" at garage entry for pex
- address over notched double floor joist above great room near windows
- address double joists above great room near stairs hole drilled greater than 3"
- address holes drilled closer than 2" in floor joist above great room near stairs
- plans call for 3 king studs either side of front entry door
- fire block W bed 3 wall to ceiling space
- missing hangers on joists above 2nd story hallway
- fire block SW master shower corner wall to ceiling space
- minimum 3 studs at exterior wall corners see basement

Comments: