

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20213741  
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                              | Inspector: | Outcome: | Date:                       |
|--|------------|----------|-----------------------------|
| <b>All Rough Inspection - Commercial</b> | Robb Popp  | Partial  | Thursday, December 01, 2022 |

Informational:

|   |      |                     |
|---|------|---------------------|
| 1 | Misc | -DATA ROOM APPROVED |
|---|------|---------------------|

Corrective Action Required:

|   |      |   |
|---|------|---|
| 2 | Misc | -Provide hanger at corner joist<br>-Protect dryer ducts<br>-Nail exterior corners<br>-Protect dwv at bath<br>-Remove dead front to inspect electrical panel |
|---|------|---|

**Comments:**