

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Thursday, December 01, 2022

Corrective Action Required:

1	Misc	-Submit updated plan to the city with omitted 2nd floor -Protect plumbing where located within 1.25" of stud/track surface. Use BOCA plates at plumbing protection at bottom track -Complete EM light electrical -Provide header detail above windows -Complete wall framing at woman restroom
---	------	--

Comments: