

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212912
Address: 1725 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, December 01, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- post permanent address- Provide final grading and sod- Provide splash blocks- Box extender at kitchen counter outlets and bar counter- Label non gfci outlets in basement- Open electrical nm 1/2 bathroom at garage door- Label non gfci outlets in garage- Garage entry door must be self closing and latch- Seal exterior penetrations- Obtain irrigation permit and submit back flow certification |
|---|------|---|

Comments: