

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223031
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, December 02, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Provide all windows- Shim 4 stud pack at header master bedroom- Secure gas line within 12" of fire place- Open lid of deck or provide ladder to inspect framing- Fb return air at penetrations bedroom 4- Over notched stud cripple wall bottom of stairs- Provide flashing for windows- Trim all windows
		Do not insulate

Comments: