

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20221459  
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Stabilized Subgrade</b>	Eric Sharp	Partial	Friday, December 02, 2022

Informational:

1 Misc

Bair crew on site grading and cutting roadways. Spoke with Shane on 11/16/22 about possibility of laying fly ash and tilling into roadway as a measure to help dry subgrade in preparation of laying geogrid and aggregate base. 11/17/22 ES

Bair crew grading roadways, dug out areas in front of some inlet boxes to take out wet fill and recompact with more suitable fill. 11/21/22 ES

11-30-22 RH. Contractor continued to place rock on top of Geogrid. 10" on aggregate is being placed on geo grid to reach proper stabilization.

12-2-22 RH. Geogrid continues to be placed around roundabout. Which aggregate will then be placed on top.

**Comments:**