

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Mitchell Schwarz	Partial	Friday, December 02, 2022

Corrective Action Required:

1	Miscellaneous Correction	- 11/22/22 LIGHT POLE BASES NO DRIVEN GROUND RODS PROVIDE REBAR CAGES PER CITY APPROVED PLANS SHEET ES101 12/2/22 Passed 2 light pole bases to pour. middle N closest to building and S most base. No ground rods still
---	--------------------------	---

Comments: