CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20225181

Address: 1121 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Grading/Excavation/Fill Ryan Heckman Partial Friday, December 02,

Inspection 2022

Informational:

1 Misc 11-4-22 RH. Site grading has started by removing vegetation before starting

to fill for the parking lot.

11-7-22 RH. Site continues to be graded for parking lot.

11-8-22 RH. Site continues to be cut down to grade and filled in certain areas.

Contractor plans to finish grading today.

11-9-22 RH. Grading was completed and contractor started placing the

Geogrid and aggregate.

12-1-22 RH. Contractor started building up detention basin.

12-2-22 RH. Contractor has almost cut dention basin to grade. Contractor also modified inlet to flow into detention basin on the higher side due to pipe

interfering with building up the wall of the detention basin.

Comments: