

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220590  
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Stabilized Subgrade</b>	John Jackson	Partial	Friday, December 02, 2022

Informational:

1	Misc	12/02/22 Friday JMJ Contractor removing unstable soil and replacing it with shotrock and MOD type 5, clean soil. Problem areas drive through outer curb line towards centerline and the outer edge to the Eastside of along the curb line and other areas with divots & piles of spoils.
---	------	--

**Comments:**