

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222245
Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	John Jackson	Partial	Friday, December 02, 2022

Informational:

1 Misc

11/22/22 Tuesday (Reike Grading)

Contractor will be working on the domestic water line. Water main was exposed for tie-in, a tee with 6" valve on the property side already exist. Water does not have this in their records and will research before they deliver meter (because no tap is needed).

12/02/22 Friday (Reike Grading)

Contractor began to layout 1" copper line. Contractor will be searching for 1" tap that is shown on GIS map runs to the outside of the road.

Comments: