

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220522
Address: 3522 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, December 05, 2022

Corrective Action Required:

1	Misc	-solid block between joists above top plate garage/foyer wall -land and secure all electrical NM, electrical boxes, bath exhaust fans duct at 2nd floor removed for repairs
---	------	--

Comments: