

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225569
Address: 2012 NE BLUESTONE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Khanh Nguyen	Failed	Tuesday, December 06, 2022

Corrective Action Required:

1	Misc	WATER LINE WAS NOT INSPECTED AND WAS NOT INSTALLED AT SEWER INSPECTION. WATER FINAL WAS CALLED BUT THE TRENCH WAS ALREADY BACKFILLED
---	------	--

Comments: