

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215067

Address: 2032 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822034 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822036 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822038 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, December 06, 2022

Corrective Action Required:

1	Misc	UNIT 2038: -complete gas line at furnace -bond gas line -gas line pressure test required
---	------	---

UNIT 2036:
- gas line bond required
(pressure ok)

UNITS 2034,2032 NO INSPECTION

Comments: