

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20221459  
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Aggregate Base</b>	Eric Sharp	Partial	Wednesday, December 07, 2022

Informational:

1 Misc

12-2-22 RH. With Geogrid placed contractor is now placing 2 lifts of 5" of aggregate base. They are then compacting the aggregate.

12-5-22 to 12-7-22 RH. Contractor continues to work the aggregate base. Soft spots were still found so they added lime to the rock base to harden it up.

**Comments:**