

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216072
Address: 524 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, December 07, 2022

Corrective Action Required:

1	Misc	-final sidewalk inspection required, contact development services to schedule -splash blocks, min 36" discharge from foundation -AFCI protection required at kitchen,dining,fridge circuits -label all breaker locations at service panel, indicate locations of bedrooms and bathrooms
---	------	--

Comments: