

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Robb Popp	Failed	Wednesday, December 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	LIGHT POLE BASES BLDG # 1 NORTH SIDE TRUCK COURT **Provide 3" clearance at rebar cages and remove all loose soil from piers
---	-----------------------------	--

Comments: