

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221592
Address: 230 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Partial	Wednesday, December 07, 2022

Informational:

1 Misc

GREASE INTERCEPTOR REAR OF BLDG
RESTROOMS NORTHWEST CORNER OF BLDG
- 11/22/22 OK TO BACKFILL GREASE INTERCEPTOR
VENT LINE INCOMPLETE AT THIS TIME -

-SANITARY LINES BUILDING 1 and 2 OK TO COVER-PROVIDE CLEANOUT IN
BUILDING 3 CHANGE OF DIRECTION

Comments: